



Pakistan Atomic Energy Commission Foundation

P.O Box No. 216

Islamabad

FHO-04/2024/Solar System

Islamabad, the 26th Feb, 2025

To: All Prospective Bidders

Subject: **Minutes of the pre-bid meeting for the "SUPPLY & INSTALLATION OF 75 KW-ON-GRID SOLAR SYSTEMS" at Pharmacy and Petrol Pumps on FOR Jauharabad and DG Khan.**

Reference: Tender notice no FHO-01/2025 dated 14-02-2025

The meeting was held at the PAEC Foundation Head Office on 24-02-2025 at 14:00 hours for subject cited above. During the meeting the interested bidders/firms have raised some queries related to Tender documents/RFP, the following clarifications/amendments have been made.

Clarifications

- 1) **Preferred Inverter Brand**
 - The preferred inverter brands are Huawei and Sungrow.
- 2) **PV Panel Requirements**
 - Only Tier-1 PV panels as per the latest Bloomberg list are accepted.
- 3) **Installation & Green Metering Activation Time line**
 - Installation time is 30 days.
 - Green Metering activation will be as per actual time required by relevant authorities.
 - The file of green meter should be submitted immediately after installation.
- 4) **Installation Structure**
 - The PV panels should be installed on the RCC structure of the Petrol Pump rather than on the Canopy.
- 5) **System Type**
 - All three systems are on-grid systems
- 6) **Payment Terms**
 - Payment will be released upon completion of each site.
- 7) **Roof layout dimensions for PV installation:**
 - FFS Jauharabad: 65 feet × 27.5 feet
 - FFS DG Khan: 10 meters × 30 meters
- 8) **Generator (Genset) Requirements**
 - The genset should be bypassed to ensure uninterrupted operation

Amendments

- 1) **Defect Liability & Warranty**
 - The defect liability period of the system is two years instead of five years.
 - Equipment warranty will be as per the OEM provisions.


AM(PP&IT)


26.02.2025
GM (Projects)